

18144

प्रपत्र सं.

(धन प्राप्ति रसीद)



उपभोक्ता प्रति

पुस्तक सं०

जलकल विभाग

रसीद सं०

रु० 2000/-

नगर निगम वाराणसी

दिनांक 19/03/2026

श्री/श्रीमती P.P.S. लाला रत्नलाल मो० नं० 0

भवन संख्या 6/वीर शम्भुपुर मुहल्ला गौराई सेवापुरी वा०

रुपया (शब्दों में) दो हजार दो सौ मात्र

नगद / चेक बैंक ड्राफ्ट दिनांक प्राप्त किया।

बिल सं० तिथि अवधि 25/2/26

देय तिथि खाता संख्या

भुगतान का विवरण

क्रम सं० १	मद २	अवशेष ३	वर्तमान ४	छूट ५	योग ३+४+५ = ६
		रु०	पै०	रु०	पै०
१	संचालित मद				
१	जलकर	रु० ७८८	पै० १२००	रु० ७८८	पै० १२००
२	स्थायी जल मूल्य				
३	अतिरिक्त जल मूल्य				
४	मीटर किराया				
५	समझौता शुल्क				
६	सीवर कर				
७	सीवर संयोजन प्रभार				
८	सर्विस चार्जेज				
९	सर चार्ज				
१०	अन्य चार्जेज				
	योग				
	असंचालित मद				
१	मीटर जमानत				
२	विकास शुल्क				
३	अन्य चार्जेज				
४	अधिभार				
	कुल योग				

(A) जल संयोजन की स्थिति - है ☐ नहीं ☐ जानकारी नहीं है ☐ (B) सीवर संयोजन की स्थिति - है ☐ नहीं ☐ जानकारी नहीं है ☐

रसीद बनाने वाले का हस्ताक्षर

अधिसासी अभियन्ता



PPENDIX-VIII

PROFARMA REGARDING SAFE DRINKING WATER
CERTIFICATE

NO- 1558

Date- 23.03.2026

It is certified that an inspection team headed by Mr Shambhu Nath (Chemist incharge) from Jalkal Vibhag Nagar Nigam Bhelupur Varanasi inspected the P.P.S. KASHI SCHOOL SHEVAPURI RAJATALAB VARANASI on 19/3/2026 and found that the Chemical and Bacteriological test of water sample is satisfactory and potable.

The above valid for a period of 06 months.

Signature:.....

जलकाली अभियन्ता (मु०,
जल कल विभाग
Name:..... नगर.नियम, वाराणसी

Designation:.....

To

P.P.S. KASHI SCHOOL
SHEVAPURI RAJATALAB
VARANASI

(Name & Address of the Institution)

जलकल विभाग नगर निगम, वाराणसी

TEST REPORT (As per IS 10500:2012)

SL NO 1554

दि 23-03-2026

Details of Samples: Testing water sample for drinking purpose (As per IS 10500:2012) Sample collected by:

Location: - P.P.S. KASHI SCHOOL SHEVAPURI RAJATALAB VARANASI

Test Date - 19/3/2026 TO 21/3/2026

Witness of person: PRINCIPAL P.P.S. KASHI SCHOOL

Sl No	Parameter	Parameter Acceptable-Permissible	Observed Values	Remarks
1	pH Value	6.5 – 8.5	7.0	
2	Turbidity (NTU)	1 – 5	0.7	
3	Iron (as Fe) mg/l	0.3 – 1.0	0.6	
4	Sulphate (as SO ₄) mg/l	200 – 400	48	
5	Chloride (as Cl) mg/l	250 – 1000	70	
6	Residual Free Chlorine mg/l	0.2 – 1.0	0.0	
7	Alkalinity as CaCO ₃ mg/l	200 – 600	192	
8	Arsenic (as As) mg/l	0.01 – 0.01	0.0	
9	MPN /100 ml	0.0 – 0.0	NILL	
10	TDS mg/l	50 – 300	105	
11	Colour (Hazen Units)	5 – 15	11	
12	Hardness as CaCO ₃ mg/l	200 – 600	185	
13	Fluoride as F mg/l	1.0 – 1.5	0.1	
14	Magnesium PPM	30 – 100	14	
15	Nitrite as NO ₃	0.2 – 0.5	NILL	
16	Nitrate as NO ₃	0.1 – 0.1	NILL	
17	Dissolved Oxygen PPM	0 – 20	8.1	
18	Taste & Odour	Unobjectionable	Unobjectionable	
19	Calcium mg/l	75 – 200	36.3	
20	Conductivity	200 – 800 µ/cm	265	

Report of suitability of water for drinking purpose

Signature - Chemist

केमिस्ट

जलकल विभाग, नगर निगम
वाराणसी